

CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Audit Information:

Utility: Rialto Water Services PWS ID: 3610038

System Type: Potable Audit Period: Calendar 2016

Utility Representation: Stephanie Stafford (operations supervisor), John Terry (project manager)

Validation Date: 7/11/2017 Call Time: 9:00am Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 68 Data Validity Band (Level): Band III (51-70)

ILI: 1.70 Real Loss: 30.06 (gal/conn/day) Apparent Loss: 14.86 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 2.2%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: William Elman / Carolyn Prescott (support) Validator Qualifications: Contractor for CA-NV AWWA Water Loss TAP

Validator Provided

CA-NV AWWA Water Loss Technical Assistance Program Wave 4 Water Audit Level 1 Validation Document

Water System Name:

Water System ID Number:

Water Audit Period: Select

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

<<Information to be completed by Utility>>

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Utility Provided

John D. Terry

Project Manager

[Signature]

9-22-2017